


G59/3 TYPE TEST VERIFICATION REPORT

| | | | |
|---|---|--|-----------------------------|
| Type Tested reference number | | YC5001 | |
| Generating Unit technology | | Grid-connected Microinverter | |
| System supplier name | | ALTENERGY POWER SYSTEM INC. | |
| Address | | No.1 Yatai Road, Jiaxing 314050 Zhejiang Province P.R. China | |
| Tel | +86-573-83986967 | Fax | +86-573-83986966 |
| E:mail | info@altenergy-power.com | Web site | https://apsystems.com / |
| Maximum export capacity, use separate sheet if more than one connection option. | 0.5 per unit | kW single phase, single, split or three phase system | |
| | | kW three phase | |
| | | kW two phases in three phase system | |
| | | kW two phases split phase system | |
| System supplier declaration. - I certify on behalf of the company named above as a supplier of a Generating Unit , that all products supplied by the company with the above Type Test reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of G59/3. | | | |
| Signed |  | On behalf of | ALTENERGY POWER SYSTEM INC. |

| Power Quality. Harmonics. Generating Unit tested to BS EN 61000-3-12 | | | | | | |
|---|---------------------------|-------|---------------------------|-------|---|---|
| Generating Unit rating per phase (rpp) | | | 6.0* | kVA | Harmonic % =Measured Value (Amps) x 23/rating per phase (kVA) | |
| Harmonic | At 45-55% of rated output | | 100% of rated output | | Limit in BS EN 61000-3-12 | |
| | Measured Value MV in Amps | % | Measured Value MV in Amps | % | 1 phase | 3 phase |
| 2 | 0.017 | 0.129 | 0.008 | 0.032 | 8% | 8% |
| 3 | 0.096 | 0.708 | 0.147 | 0.543 | 21.6% | Not stated |
| 4 | 0.006 | 0.051 | 0.004 | 0.014 | 4% | 4% |
| 5 | 0.062 | 0.457 | 0.107 | 0.397 | 10.7% | 10.7% |
| 6 | 0.004 | 0.03 | 0.003 | 0.011 | 2.67% | 2.67% |
| 7 | 0.042 | 0.313 | 0.084 | 0.31 | 7.2% | 7.2% |
| 8 | 0.003 | 0.022 | 0.002 | 0.01 | 2% | 2% |
| 9 | 0.054 | 0.402 | 0.101 | 0.375 | 3.8% | Not stated |
| 10 | 0.002 | 0.021 | 0.002 | 0.009 | 1.6% | 1.6% |
| 11 | 0.076 | 0.563 | 0.156 | 0.577 | 3.1% | 3.1% |
| 12 | 0.002 | 0.02 | 0.002 | 0.007 | 1.33% | 1.33% |
| 13 | 0.092 | 0.677 | 0.18 | 0.665 | 2% | 2% |
| THD | | 2.052 | | 1.89 | 23% | 13% |
| PWHD | | 6.984 | | 6.425 | 23% | 22% |
| *system size is scalable;this is the system size tesed(12 units) | | | | | | |
| Power Quality. Harmonics. Generating Unit tested to BS EN 61000-3-2 | | | | | | |
| Generator Unit rating per phase (rpp) | | | 3 | kW | | |
| Harmonic | At 45-55% of rated output | | 100% of rated output | | | |
| | Measured Value MV in Amps | | Measured Value MV in Amps | | Limit in BS EN 61000-3-2 in Amps | Higher limit for odd harmonics 21 and above |

| | | | | |
|----|-------|-------|-------|-------|
| 2 | 0.01 | 0.017 | 1.080 | |
| 3 | 0.043 | 0.096 | 2.300 | |
| 4 | 0.004 | 0.006 | 0.430 | |
| 5 | 0.018 | 0.062 | 1.140 | |
| 6 | 0.003 | 0.004 | 0.300 | |
| 7 | 0.015 | 0.042 | 0.770 | |
| 8 | 0.002 | 0.003 | 0.230 | |
| 9 | 0.02 | 0.054 | 0.400 | |
| 10 | 0.002 | 0.002 | 0.184 | |
| 11 | 0.039 | 0.076 | 0.330 | |
| 12 | 0.002 | 0.002 | 0.153 | |
| 13 | 0.046 | 0.092 | 0.210 | |
| 14 | 0.001 | 0.002 | 0.131 | |
| 15 | 0.054 | 0.109 | 0.150 | |
| 16 | 0.001 | 0.001 | 0.115 | |
| 17 | 0.048 | 0.089 | 0.132 | |
| 18 | 0.001 | 0.001 | 0.102 | |
| 19 | 0.044 | 0.085 | 0.118 | |
| 20 | 0.001 | 0.001 | 0.092 | |
| 21 | 0.039 | 0.076 | 0.107 | 0.160 |
| 22 | 0.001 | 0.001 | 0.084 | |
| 23 | 0.032 | 0.057 | 0.098 | 0.147 |
| 24 | 0.001 | 0.001 | 0.077 | |
| 25 | 0.024 | 0.048 | 0.090 | 0.135 |
| 26 | 0.001 | 0.001 | 0.071 | |
| 27 | 0.021 | 0.045 | 0.083 | 0.124 |
| 28 | 0.001 | 0.001 | 0.066 | |
| 29 | 0.017 | 0.034 | 0.078 | 0.117 |
| 30 | 0.001 | 0.001 | 0.061 | |

| | | | | |
|----|-------|-------|-------|-------|
| 31 | 0.016 | 0.031 | 0.073 | 0.109 |
| 32 | 0.001 | 0.001 | 0.058 | |
| 33 | 0.017 | 0.035 | 0.068 | 0.102 |
| 34 | 0.001 | 0.001 | 0.054 | |
| 35 | 0.011 | 0.027 | 0.064 | 0.096 |
| 36 | 0.001 | 0.001 | 0.051 | |
| 37 | 0.003 | 0.008 | 0.061 | 0.091 |
| 38 | 0.001 | 0.001 | 0.048 | |
| 39 | 0.002 | 0.006 | 0.058 | 0.087 |
| 40 | 0.001 | 0.001 | 0.046 | |

| Power Quality. Voltage fluctuations and Flicker. Tested to BS EN 61000-3-11 | | | | | | | | |
|---|----------|-----------------|------|----------|-------|------------------|---------|--------------|
| | Starting | | | Stopping | | | Running | |
| | d max | d c | d(t) | d max | d c | d(t) | P st | P lt 2 hours |
| Measured Values at test impedance | 0.88% | 0.62% | 0 | 0.88% | 0.61% | 0 | 0.15 | 0.15 |
| Normalised to standard impedance | 0.88% | 0.62% | 0 | 0.88% | 0.61% | 0 | 0.15 | 0.15 |
| Normalised to required maximum impedance | 0.88% | 0.62% | 0 | 0.88% | 0.61% | 0 | 0.15 | 0.15 |
| Limits set under BS EN 61000-3-11 | 4% | 3.3% | 3.3% | 4% | 3.3% | 3.3% | 1.0 | 0.65 |
| | | | | | | | | |
| Test Impedance | R | 0.4 | | Ω | XI | 0.25 | Ω | |
| Standard Impedance | R | 0.24 * 0.4 ^ | | Ω | XI | 0.15 * 0.25 ^ | Ω | |
| Maximum Impedance | R | 0.4 | | Ω | XI | 0.25 | Ω | |

| Power quality. DC injection. | | | | |
|------------------------------|-------|-------|-------|--|
| Test power level | 10% | 55% | 100% | |
| Recorded value in Amps | 0.002 | 0.004 | 0.012 | |
| as % of rated AC current | 0.01% | 0.01% | 0.04% | |
| Limit | 0.25% | 0.25% | 0.25% | |

| Power Quality. Power factor. | | | | |
|------------------------------|--------|-------|-------|---|
| | 216.2V | 230V | 253V | Measured at three voltage levels and at full output. Voltage to be maintained within + or – 1.5% of the stated level during the test. |
| Measured value | 0.99 | 0.99 | 0.99 | |
| Limit | >0.95 | >0.95 | >0.95 | |

| Protection. Frequency tests | | | | | | |
|-----------------------------|-----------|------------|-----------|------------|------------------|-----------------|
| Function | Setting | | Trip test | | "No-trip tests" | |
| | Frequency | Time delay | Frequency | Time delay | Frequency /time | Confirm no trip |
| O/F stage 1 | 51.5Hz | 90s | 51.54Hz | 90.3s | 51.3Hz 95s | Confirmed |
| O/F stage 2 | 52Hz | 0.5s | 51.95Hz | 0.55s | 51.8Hz 89.98s | Confirmed |
| | | | | | 52.2Hz 0.48s | Confirmed |
| U/F stage 1 | 47.5Hz | 20s | 47.51Hz | 20.25s | 47.7Hz 25s | Confirmed |
| U/F stage 2 | 47Hz | 0.5s | 47.02Hz | 0.61s | 47.2Hz 19.98s | Confirmed |
| | | | | | 46.8 Hz 0.48s | Confirmed |

| Protection. Voltage tests | | | | | | |
|---------------------------|---------|------------|-----------|------------|--|-----------------|
| Function | Setting | | Trip test | | "No trip-tests" All phases at same voltage | |
| | Voltage | Time delay | Voltage | Time delay | Voltage /time | Confirm no trip |
| O/V stage 1 | 262.2V | 1.0s | 262V | 1.08s | 258.2V 2.0s | Confirmed |
| O/V stage 2 | 273.7V | 0.5s | 274V | 0.51s | 269.7V 0.98s | Confirmed |
| | | | | | 277.7V 0.48s | Confirmed |
| U/V stage 1 | 200.1V | 2.5s | 200V | 2.84s | 204.1V 3.5s | Confirmed |
| U/V stage 2 | 184V | 0.5s | 184V | 0.51 | 188V 2.48s | Confirmed |
| | | | | | 180v 0.48s | Confirmed |

| | | | | | | |
|--|--------------------------------------|--------------------------------------|--------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|
| a) Protection. Loss of Mains test and single phase test. The tests are to be To be carried out at three output power levels plus or minus 5%, an alternative for inverter connected Generating Units can be used instead. | | | | | | |
| To be carried out at three output power levels plus or minus 5%, an alternative for inverter connected Generating Units can be used instead. | | | | | | |
| Test Power | 10% | 55% | 100% | 10% | 55% | 100% |
| Balancing load on islanded network | 95% of Generating Unit output | 95% of Generating Unit output | 95% of Generating Unit output | 105% of Generating Unit output | 105% of Generating Unit output | 105% of Generating Unit output |
| Trip time. Limit is 0.5s | 0.265s | 0.252s | 0.199s | 0.266s | 0.296s | 0.460s |

| b) Protection. Frequency change, Stability test | | | | |
|---|-----------------|------------------------|---------------|-----------------|
| | Start Frequency | Change | End Frequency | Confirm no trip |
| Positive Vector Shift | 49.5Hz | +9 degrees | | Confirmed |
| Negative Vector Shift | 50.5Hz | - 9 degrees | | Confirmed |
| Positive Frequency drift | 49.5Hz | +0.19Hzs ⁻¹ | 51.5Hz | Confirmed |
| Negative Frequency drift | 50.5Hz | -0.19Hzs ⁻¹ | 47.5Hz | Confirmed |

| c) Protection. Re-connection timer. | | | | | |
|--|--------------------|--|-----------|-----------|-----------|
| Time delay setting (s) | Measured delay (s) | Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 10.5.7.1. | | | |
| 30 | 31.5s | At 266.2V | At 196.1V | At 47.4Hz | At 51.6Hz |
| Confirmation that the Generating Unit does not re-connect | | Confirmed | Confirmed | Confirmed | Confirmed |

| d) Fault level contribution. | | | | | |
|--|----------|-------|---------------------|---------|------------|
| For machines with electro-magnetic output | | | For Inverter output | | |
| Parameter | Symbol | Value | Time after fault | Volts | Amps |
| Peak Short Circuit current | i_p | | 20ms | 45.74 | 5.98 |
| Initial Value of aperiodic current | A | | 100ms | 34.47 | 6.36 |
| Initial symmetrical short-circuit current* | I_k | | 250ms | | |
| Decaying (aperiodic) component of short circuit current* | i_{DC} | | 500ms | | |
| Reactance/Resistance Ratio of source* | X/R | | Time to trip | 106.4ms | In seconds |

| | |
|--|--------|
| e) Self Monitoring solid state switching | Yes/NA |
| It has been verified that in the event of the solid state switching device failing to disconnect the Generating Unit , the voltage on the output side of the switching device is reduced to a value below 50 Volts within 0.5 seconds | NA |

| Additional comments |
|---------------------|
| |